

Compliance Basics (Review)

Upgrading Steel Tanks: Three choices

- 1. Add cathodic protection**
- 2. Internal lining**
- 3. Both cathodic protection and internal lining**

How were tanks upgraded?

Was an assessment done prior to adding CP?

Are tightness test results available?

Is owner doing monthly monitoring?

Compliance Basics (Review)

Upgrading Piping: Two choices

- 1. Add cathodic protection**
- 2. Replace with corrosion resistant piping**

Was a corrosion expert involved if piping was upgraded with CP?

Were tightness tests done?

Was the state notified if piping was replaced?

Compliance Basics (Review)

Spill Prevention

Must prevent release when hose is disconnected

Do you have these in place?

Are they being properly maintained?